

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Saia-Burgess Controls AG		
Product name	Saia PCD1 / PCD2 Line		
Product model number	PCD1.M2110R1 (PCD1.Room), PCD1.M2120, PCD1.M2160, PCD1.M2220_C15, PCD2.M4160, PCD2.M4560		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.14
Firmware revision	1.28.19		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 19200, 38400, 57600, 115200	
	<input type="checkbox"/>	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input checked="" type="checkbox"/> Router, medium: BACnet/IP – MS/TP, MS/TP – MS/TP	
Character set	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/>	AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/>	AMEV profile AS-B (Automation station, extended version)	As of: AMEV BACnet 2017
<input type="checkbox"/>	AMEV profile	As of:

3. Basis for AMEV attestation:

<input checked="" type="checkbox"/>	Test report of test lab MBS dated 17.10.2017 number VG 2017_15623
<input checked="" type="checkbox"/>	AMEV recommendation BACnet 2017 As of: 01.08.2018 (see www.amev-online.de)

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/>	Certificate number BTL-30219 (see http://www.bacnetinternational.net/btl)
-------------------------------------	---

Stuttgart, 13.12.2017



Dr.-Ing. Bernhard Hall
Vermögen und Bau Baden-Württemberg
Rotebühlplatz 30
70195 Stuttgart
Telefon +49 711 6673-3433
Email Bernhard.Hall@vbw.bwl.de

(AMEV chairman BACnet)

WSP CERT



Dr.-Ing. Frank Bitter
Kapuzinerweg 7
70374 Stuttgart
Germany

(BACnet certification body)