

WSPCert Certificate

No. BAC-0143-03

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The 4 BACnet Building Controllers (B-BC)

Saia PCD1 Line

**PCD1.M0160E0 E-Controller, PCD1.M2120,
PCD1.M2110R1 PCD1.Room, PCD1.M2160
with Modules PCD7.R560 or PCD7.R562**

with the software version:

1.22.29

of


Saia-Burgess Controls AG

Bahnhofstrasse 18, 3280 Murten, Switzerland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 9.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2012_7293**.

The certificate is valid
until 2017/04/01

Date of renewal
2016/03/31



2014/04/01

Date of initial certification



A handwritten signature in black ink, appearing to be 'G. Weinmann', written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body

Annex to Certificate No. BAC-0143-03

The certification of the BACnet Implementations
Saia PCD1 Line
of **Saia-Burgess Controls AG**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

| BACnet Interoperability Building Blocks | |
|--|---|
| DS-RP-A | Data Sharing – Read Property – A |
| DS-RP-B | Data Sharing – Read Property – B |
| DS-RPM-A | Data Sharing – Read Property Multiple – A |
| DS-RPM-B | Data Sharing – Read Property Multiple – B |
| DS-WP-A | Data Sharing – Write Property – A |
| DS-WP-B | Data Sharing – Write Property – B |
| DS-WPM-B | Data Sharing – Write Property Multiple – B |
| DS-COV-A | Data Sharing – COV – A |
| DS-COV-B | Data Sharing – COV – B |
| AE-N-I-B | Alarm and Event – Notification Internal – B |
| AE-N-E-B | Alarm and Event – Notification External – B |
| AE-ACK-B | Alarm and Event – Acknowledge Alarm – B |
| AE-INFO-B | Alarm and Event – Information – B |
| AE-ASUM-B | Alarm and Event – Alarm Summary – B |
| AE-ESUM-B | Alarm and Event – Event-Enrollment Summary-B |
| SCHED-I-B | Scheduling – Internal – B |
| SCHED-E-B | Scheduling – External – B |
| T-VMT-I-B | Trending – Viewing and Modifying Trends Internal – B |
| T-VMT-E-B | Trending – Viewing and Modifying Trends External – B |
| T-ATR-B | Trending – Automated Trend Retrieval – B |
| T-VMMV-I-B | Trending – Viewing and Modifying Multiple Values Internal – B |
| T-VMMV-E-B | Trending – Viewing and Modifying Multiple Values External – B |
| T-AMVR-B | Trending – Automated Multiple Value Retrieval – B |
| DM-DDB-A | Device Management – Dynamic Device Binding – A |
| DM-DDB-B | Device Management – Dynamic Device Binding – B |
| DM-DOB-A | Device Management – Dynamic Object Binding – A |
| DM-DOB-B | Device Management – Dynamic Object Binding – B |
| DM-DCC-B | Device Management – Device Communication Control – B |
| DM-ATS-A | Device Management – Automatic Time Synchronization – A |
| DM-TS-A | Device Management – Time Synchronisation – A |
| DM-TS-B | Device Management – Time Synchronisation – B |
| DM-UTC-A | Device Management – UTC Time Synchronisation – A |
| DM-UTC-B | Device Management – UTC Time Synchronisation – B |
| DM-RD-B | Device Management – Reinitialize Device – B |

(continued)

Annex to Certificate No. BAC-0143-03

The certification of the BACnet Implementations
Saia PCD1 Line
of **Saia-Burgess Controls AG**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

(continued)

| BACnet Interoperability Building Blocks | |
|--|--|
| DM-BR-B | Device Management – Backup and Restore – B |
| DM-R-B | Device Management – Restart– B |
| DM-LM-B | Device Management – List Manipulation– B |
| DM-OCD-B | Device Management – Object Creation and Deletion – B |