## PCD3.M+xx0 FW 1.16.69 Release Notes

#### 1 **Summary of Firmware versions**

This summary presents a short description of all firmware versions which are set on PCD3Mxxxx at the production (official versions and exceptionally some intermediate versions \$).

## 2 **Important:**



Update to this FW from a version ≤ 1.14.xx deletes the RAM DB/Text, the medias and the onboard file system (INTFLASH) is formatted, all data on this partition (file system, backup program & DB's) are deleted. The program is not lost!



To take the full advantages of the PCD3 features PG5 2.0 SP1 or newer is required.

Delete the SRAM & internal file system on Power-On with push button: After a power-on hold the push button during system start until the run/halt LED is flashing red (4Hz). If the button is released in this section the SRAM will be deleted and the system starts like no battery and empty SuperCAP. If the push button holds longer until the run/halt LED is flashing alternate the SRAM will be deleted and the internal file system is format.

Filename: PCD3.Mxx60\_1.16.69 Page 1/7 Date:27/06/2012

## 3 Features or restrictions specifications

#### 3.1 General

 Needed Programming Tool Not usable with PG3 & PG4

To program a PCD3.M+xx0 a PG5 V \$2.0.124 or newer has to be used.

FBox library

The Fbox of the analogue modules W1, W2 & W5 only working from PG5 V \$1.3.010 or newer.

FW update

The FW can be updated with the FWdnld.exe program located in the PG5 directory.

CPLD programming:

There is no CPLD programming.

- Default PGU mode is S-BUS parity
- The user program is stored in the internal SD-Card memory.
- The Configuration is stored in the internal SD-Card memory.
- The external Program backup is only possible to a File system device.
- New Configuration with PG5 2.0 SPI for:

1.14.00

- o FTP /File system
- New web-server / HTTP direct
- o TCPIP/ enhancements:
  - DHCP/DNS
  - SNTP
  - PPP
  - SNMP
- o Bluetooth

•	Program Backup as backup File	1.16.22
	- backup file ".SBAK"	1.16.22
	- Configuration Backup to backup File (only for ".SBAK" file)	1.16.22
	- Media Backup to backup File (only for ".SBAK" file)	1.16.22
•	Clear Mapped Media	1.16.42

#### 3.2 Not implemented features on PCD3.M+xx0

- Mode MM4
- LAN2:
- Mode D
- S-Bus-RIO as master.
- PROFIBUS FMS
- LON
- Program backup to PCD7.R500

1.14.00

#### 3.3 Memory

User memory:

System	HW	User memory		Onboard File
	Revision	Code/Text (ROM)	Ext. (RAM)	System
M5560	-	2 Mbytes	1 Mbytes	16 Mbytes
M6360		-	-	,
M6560				



Note: At first memory configuration the FW makes an allocation with the maximum space available depending on the RAM/EPROM/FLASH chip.

• EEPROM: 1.14.00

- The S-Bus configuration is automatically saved in the EEPROM, this
  means that even if the battery or super cap becomes discharged the SBus configuration will be safe.
- There are 50 non-volatile user registers.
- Registers:

•	rtegisters.	
	- Up to 16383 Registers	1.14.00
•	Flags:	
	- Up to 14336 Flags	1.14.02
•	DB backup (SYSWR 3xxx):	
	- Fix size for onboard flash 256kB	1.16.24

1.14.00

#### **Instructions**

Please refer to the following list which indicates the first firmware version used in production supporting the relevant feature.

in	production supporting the relevant feature.	
•	SYSWR 900x or SYSWR 300x	1.14.00
•	Peripheral instructions	1.14.00
•	PB, FB Temporary Data	1.14.00
•	2000 FB's, 1000 PB's, 32 COB's	1.14.00
•	FB call depth of 31.	1.14.00
•	IEEE floating point instruction for single and double	1.14.00
•	Signed extension instruction EXTB, EXTW	1.14.00
•	SF for text	1.14.00
3.	4 Communication	
•	Serial port  The port 0 has no more RS 232/RS485 switch  The port 0 have a full RS 232 (a modem can be equipped)  The port 1 have a full RS 232 if it is equipped with F121  The port 2 is for RS485 & Profi-S-Net  The port 3 is for RS485 or Profi-S-Net as port 10	1.14.00 1.14.00 1.14.00 1.14.00 1.14.00
•	New Serial port with PCD3.F2xx - Port 100 & 101 on Slot 0 - Port 110 & 111 on Slot 1 - Port 120 & 121 on Slot 2 - Port 130 & 131 on Slot 3	1.14.00 1.14.00 1.14.00 1.14.00
•	Serial communication: - Baudrates up to 115k Baud on port 0,1 & 2 - No Baudrates < 1200 on all port	1.14.00 1.14.00
•	S-Bus:  - Baudrates up to 115k Baud on port 0,1 & 2  - No break modes as master and slave.  - No parity modes as master (SM1) on port 0 & 3.  - CSF for Send/Recv.	1.14.00 1.14.00 1.14.00 1.14.00
•	Modem: - Auto answer modem on port 0 and 1 (analog & ISDN)	1.14.00
•	PROFIBUS DP:  - Transfer of signed values possible, with PG5 SP1.4.120 or newer  - Master mode on Port 10 with PCD3.M6440 / PCD3.M6540  - Slave mode with MPI/S-Net port 10.	1.14.00 1.14.00 1.14.00

Slave mode with MPI/S-Net port 2 (with maximal baudrate = 187.5Kb).

# **Saia-Burgess** Controls Ltd. Bahnhofstrasse 18 I CH-3280 Murten I Switzerland T +41 (0)26 672 71 11 I F +41 (0)26 670 44 43

•	<ul> <li>Profi-S-IO:</li> <li>Transfer of signed values possible, with PG5 SP1.4.120 or newer</li> <li>Master / Slave mode with MPI/S-Net port 10.</li> <li>Master / Slave mode with MPI/S-Net port 2 (with maximal baudrate = 187.5Kb)</li> <li>MPI for Terminal R/W OP (please contact SAIA-Burgess Controls for more information)</li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00
•	Communication on TCP_IP:  - Classless inter domain router  - S-Bus over IP  - "Open data mode" over IP with max. 32 ports / 32 connections  - S-Bus GWY Master over IP  - 255 ARP table entries	1.14.00 1.14.00 1.14.00 1.14.00 1.14.00
•	WEB server	1.14.00
•	WEB server with HTTP direct connection	1.14.00
•	WebServer2	1.14.00
•	PPP (Point to Point Protocol)  - Configuration through file, WEB-CGI and CSF  - No FBox support  - All serial ports available	1.14.00
•	SNTP (Simple Network Time Protocol)  – Configuration through file and WEB-CGI	1.14.00
•	DHCP	1.14.00
•	DNS	1.14.00
•	SNMP	1.14.00
•	PING	1.14.03
•	Config Tags for eDisplay	1.14.00
•	PGU switches automatically to 115 kBds.	1.14.00
•	No limitation with the baudrate configured/assigned.	1.14.00
•	Profi-S-Bus:	
	Master & Slave mode with MPI/S-Net port 10.	1.14.00
	Profi-S-Bus GWY Master.	1.14.00
•	Multi PGU (incl. modem)	1.14.00
•	S-Bus over USB	1.14.00
•	CAN on Port 10, PCD3.M6340 only (PG5 V\$1.3.127 or higher)	1.14.00
•	RS422/RS485 on port 3 of PCD3.M5240 and PCD3.M5340	1.14.00
•	MODBUS Driver over TCPIP, UDP and serial  - Accessible over CSF calls only	1.14.00

Filename: PCD3.Mxx60\_1.16.69

Saia-Burgess Controls Ltd.  Bahnhofstrasse 18 I CH-3280 Murten I Switzerland T +41 (0)26 672 71 11 I F +41 (0)26 670 44 43	
<ul><li>Serial port 0, 1, 2 and 3.</li><li>No support for F2xx serial lines (port 100 131)</li></ul>	
<ul> <li>Lon IP</li> <li>Support the LonIP Module PCD3/7.R580/581.</li> </ul>	1.14.00
<ul><li>Ether-S-IO</li><li>Support Ether-S-IO RIO</li></ul>	1.16.00
<ul> <li>M-BUS Communication modules supported (PCD2.F2700, PCD2.F27 PCD2.F2720, PCD2.F2730)</li> </ul>	
- Support for these modules with "Frame" protocol	1.16.48
<ul> <li>DALI Communication modules supported (PCD2.F2610)</li> <li>Support for these modules with "Frame" protocol</li> </ul>	1.16.48
3.5 Miscellaneous	
<ul> <li>IL code of analogue modules W1, W2 &amp; W5 must change (see manua</li> </ul>	l). <b>1.14.00</b>
New features for PG5.  New OUTL and OUTLY instructions.	1.14.00
<ul> <li>New OUTL and OUTLX instructions</li> </ul>	
<ul> <li>New SUTE and OUTEX instructions</li> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized management</li> </ul>	anner.
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized ma</li> <li>XOB</li> </ul>	
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized ma</li> <li>XOB</li> <li>XOB 20-21: interrupt inputs XOB's</li> </ul>	1.14.00
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized ma</li> <li>XOB</li> </ul>	
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized material</li> <li>XOB</li> <li>XOB 20-21: interrupt inputs XOB's</li> <li>XOB 14, 15, 25-29 Time Cyclic Alarm         <ul> <li>can be executed from 1 ms to 1000s with 1ms steps</li> <li>can be executed only one time with SYSWR 41xx</li> </ul> </li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized material</li> <li>XOB</li> <li>XOB 20-21: interrupt inputs XOB's</li> <li>XOB 14, 15, 25-29 Time Cyclic Alarm         <ul> <li>can be executed from 1 ms to 1000s with 1ms steps</li> <li>can be executed only one time with SYSWR 41xx</li> </ul> </li> <li>XOB 17, 18, 19: User XOB's</li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00 1.14.00
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized material</li> <li>XOB</li> <li>XOB 20-21: interrupt inputs XOB's</li> <li>XOB 14, 15, 25-29 Time Cyclic Alarm         <ul> <li>can be executed from 1 ms to 1000s with 1ms steps</li> <li>can be executed only one time with SYSWR 41xx</li> </ul> </li> <li>XOB 17, 18, 19: User XOB's         <ul> <li>This XOB's which can be provoked via S-BUS telegram (STXM chan, 0, k 4000, k 1719) or SYSWR command (K4017K401</li> </ul> </li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00 1.14.00
<ul> <li>New synchronization for a bloc downloads in mode "RUN"</li> <li>Possibility to upload data (SEDIT and SFUP) in a synchronized material</li> <li>XOB</li> <li>XOB 20-21: interrupt inputs XOB's</li> <li>XOB 14, 15, 25-29 Time Cyclic Alarm can be executed from 1 ms to 1000s with 1ms steps can be executed only one time with SYSWR 41xx</li> <li>XOB 17, 18, 19: User XOB's This XOB's which can be provoked via S-BUS telegram (STXM)</li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00 1.14.00

	CONDITIONAL RUN.	
-	XOB 7: System overload XOB	1.14.00
-	XOB 1 and 2 Status call (see manual)	1.14.00
-	XOB 1 and 2 Status call (see manual)	1.14.00
_	New XOB handling	

The XOB's are split in 2 priorities. A higher prior XOB can interrupt the lower prior XOB. (see manual)

-	XOB 32-63: configurable for CAN (PCD3.M6340, PG5 V\$1.3.127)	1.14.00
-	XOB 3 for task and Task data overflow	1.10.16

Calculation of week and day number 1.14.00 The PCD compute the day and the week number based on the date using the same algorithm as in the PG. The command 'Write Clock' corrects automatically the week number or day number if they are wrong.

Password mechanism. 1.14.00

Saja-burgess
tems and C

Saia-Burgess Controls Ltd.  Bahnhofstrasse 18 I CH-3280 Murten I Switzerland T +41 (0)26 672 71 11 I F +41 (0)26 670 44 43	
<ul> <li>Copy user program from flash to SRAM without PG</li> </ul>	1.14.00
<ul> <li>File system.</li> <li>CSF asynchron</li> <li>6 File devices (2 internal, 4 external Flashcards)</li> <li>Onboard File system for configuration files</li> </ul>	1.14.00 1.14.00 1.14.00 1.14.00
FTP server	1.14.00
• Flash Modules PCD3.R5xx are supported on the IO Slot	ts 03 <b>1.14.00</b>
SD Flash Modules PCD3.R6xx are supported on the IO	Slots 03 <b>1.14.00</b>
- Allow to overwrite data on a SD card (PCD3.R600) fi	le system. <b>1.14.00</b>
<ul><li>Alarm DB</li><li>Number of parameters changed</li></ul>	1.14.00 1.14.00
Data Initialisation DBX	1.14.00
"Memory lost" history entry	1.14.00
"I/O Module B160" supported	1.16.51

# 4 Information for FW updating.